107277


Fort Nelson (Military Museum)
Reservoir (covered)
Nelson's Monument
Portsdown Hill Road
Portsdown Hill Road
Portsdown Hill Road

Southern Water

RECEIVED
21 NOV 2016

Odyssey
Tuscany House
White Hart Lane
Basingstoke
Hampshire
RG21 4AF

BAC.....
SRB.....
HB.....
RS.....
ACC.....

Developer Services
Southern Water
Sparrowgrove House
Sparrowgrove
Otterbourne
Hampshire
SO21 2SW

Tel: **0330 303 0119**
Email: ***developerservices@southernwater.co.uk***

Your Ref:

Our Ref:
CC/003144

F.A.O: Mr. Bernard Thuku ,

Date:
16 November 2016

Site: Land East of Downend Road, Fareham, Hampshire, PO16 8QF.

Dear Sirs,

I am now in receipt of the results of the capacity check you requested for the above development site.

FOUL WATER

Following initial investigations, there is currently adequate capacity in the local sewerage network to accommodate a foul flow from proposed development site at/downstream of manhole reference SU60068301. Please note that no surface water flows (existing or proposed) can be accommodated within the existing foul sewerage system.

Before any connection/s are made, an application form needs to be completed and approved by Southern Water Services.

Please let me know if we can be of any further assistance in this matter.

Yours faithfully,

David Akehurst
Developer Services

Please note: -
The information provided above does not grant approval for any designs/drawings submitted for the capacity analysis. The results quoted above are only valid for 12 months from the date of issue of this letter.

SOUTHERN WATER



Sewer Plan

Scale: 1:1250

Printed by: Rosps

Site Location: Plan

Requested By:

Southern Water

APPENDIX H

Proposed Drainage Strategy and Micro Drainage Calculations

REPRODUCED FROM ORDNANCE SURVEY ® BY THE PERMISSION OF THE CONTROLLER OF HER MAJESTY'S STATIONERY OFFICE. © CROWN COPYRIGHT. ALL RIGHTS RESERVED. LICENCE NUMBER 100045322.

NOTES

1. DO NOT SCALE FROM THIS DRAWING. WORK FROM FIGURED DIMENSIONS ONLY.
2. ALL DIMENSIONS SHOWN ON THIS DRAWING ARE IN METRES.
3. THE SUDS DESIGN IS BASED ON THE PRELIMINARY SOAKAWAY TEST RESULTS THAT WERE OBTAINED ON SITE BY GEO-ENVIRONMENTAL IN JULY 2020.
4. THE POSITION AND DIMENSIONS OF BASINS SHOULD BE REVIEWED ONCE FURTHER SITE INVESTIGATIONS, INCLUDING GROUNDWATER MONITORING AND CHALK CLASSIFICATION, HAVE BEEN CARRIED OUT ON SITE.
5. IF THE FURTHER SITE TESTING RESULTS ARE DEEMED UNFAVORABLE, ADDITIONAL CONNECTION PIPES AND / OR PUMPING STATION MAY BE REQUIRED AT THE OUTFALL OF THE PROPOSED INFILTRATION BASINS.
6. AN EASEMENT OF 15m HAS BEEN APPLIED BETWEEN THE NETWORK RAIL BOUNDARY AND THE PROPOSED INFILTRATION BASINS.
7. ALL SUDS DEVICES HAVE BEEN SIZED TO ACCOMMODATE ALL SURFACE WATER RUNOFF UP TO A 1 IN 100 YEAR (INCLUDING 40% CLIMATE CHANGE ALLOWANCE) RETURN PERIOD STORM EVENT.
8. IN ORDER TO FULFIL THE SURFACE WATER TREATMENT REQUIREMENTS, AN ADDITIONAL SUDS SOURCE CONTROL DEVICE, SUCH AS PERMEABLE PAVING, SWALES AND FILTER STRIPS ETC, SHOULD BE INCORPORATED INTO THE DESIGN PRIOR TO SURFACE WATER RUNOFF BEING DISCHARGED INTO THE BASIN.

LEGEND

- SITE BOUNDARY
- DEVELOPABLE AREA DRAINING TO INFILTRATING BASIN 1
- DEVELOPABLE AREA TO INFILTRATING BASIN 2
- DEVELOPABLE AREA DRAINING TO BASIN 3
- DEVELOPABLE AREA DRAINING TO BASIN 4
- LIDAR DTM 1m CONTOUR
- PROPOSED INFILTRATION BASIN
- PROPOSED ADOPTABLE FOUL RISING MAIN
- PROPOSED ADOPTABLE FOUL PUMPING STATION

Rev	Amendments	Drn	Chk	App	Date
F	SUDS DESIGN UPDATED TO LATEST MASTERPLAN	NM	NA	GG	21.07.20
E	SUDS DESIGN UPDATED TO LATEST MASTERPLAN	CF	NA	GG	11.10.17
D	SUDS DESIGN UPDATED TO LATEST MASTERPLAN	CF	JH	GG	07.09.17
C	SUDS DESIGN UPDATED TO LATEST SOAKAWAY TESTS; SW PUMPING STATION ADDED.	JH	GG	GG	20.02.17
B	SUDS DESIGN UPDATED TO LATEST MASTERPLAN; FW DRAINAGE ADDED.	JH	GG	GG	23.01.17
A	SUDS DESIGN AMENDED BASED ON PRELIMINARY SOAKAWAY TEST RESULTS	JH	TG	GG	23.12.16

ODYSSEY

Tuscany House
White Hart Lane
Basingstoke
Hampshire RG21 4AF

Telephone: 01256 331144
Fax: 01256 331134
E: info@odysseyconsult.co.uk
W: www.odysseyconsult.co.uk

Job Title
WINNHAM FARM,
DOWNEND ROAD, PORTCHESTER

Drawing Title
PROPOSED DRAINAGE STRATEGY

Client
MILLER HOMES

Scale	Date	Designed
1:1000 @A1	NOV 16	JH
Drawn	**Checked**	**Approved**
JH	TG	GG
Job No	**Drawing No**	**Rev**
16-329	16-329/002	F

P:\16-329 - Land East of Downend Road, Portchester\TechAcad\Drawings\16-329-002 Proposed Drainage Strategy.dwg

Summary of Results for 100 year Return Period (+40%)

Half Drain Time : 3800 minutes.

Storm Event	Max Level (m)	Max Depth (m)	Max Infiltration (l/s)	Max Volume (m³)	Status
15 min Summer	22.501	0.401	0.5	103.0	O K
30 min Summer	22.580	0.480	0.6	128.3	O K
60 min Summer	22.669	0.569	0.6	159.6	O K
120 min Summer	22.770	0.670	0.7	197.8	O K
180 min Summer	22.833	0.733	0.8	223.7	O K
240 min Summer	22.880	0.780	0.8	243.7	O K
360 min Summer	22.948	0.848	0.9	274.1	O K
480 min Summer	22.998	0.898	0.9	297.0	O K
600 min Summer	23.036	0.936	0.9	315.4	O K
720 min Summer	23.067	0.967	1.0	330.7	O K
960 min Summer	23.089	0.989	1.0	342.0	O K
1440 min Summer	23.113	1.013	1.0	354.2	Flood Risk
2160 min Summer	23.122	1.022	1.0	359.1	Flood Risk
2880 min Summer	23.118	1.018	1.0	357.0	Flood Risk
4320 min Summer	23.125	1.025	1.0	360.7	Flood Risk
5760 min Summer	23.125	1.025	1.0	360.5	Flood Risk
7200 min Summer	23.119	1.019	1.0	357.7	Flood Risk
8640 min Summer	23.111	1.011	1.0	353.3	Flood Risk
10080 min Summer	23.100	1.000	1.0	347.9	Flood Risk
15 min Winter	22.540	0.440	0.5	115.4	O K

Storm Event	Rain (mm/hr)	Flooded Volume (m³)	Time-Peak (mins)
15 min Summer	134.458	0.0	19
30 min Summer	83.947	0.0	34
60 min Summer	52.411	0.0	64
120 min Summer	32.722	0.0	124
180 min Summer	24.841	0.0	184
240 min Summer	20.430	0.0	244
360 min Summer	15.509	0.0	364
480 min Summer	12.755	0.0	482
600 min Summer	10.960	0.0	602
720 min Summer	9.683	0.0	722
960 min Summer	7.687	0.0	962
1440 min Summer	5.551	0.0	1442
2160 min Summer	4.009	0.0	2160
2880 min Summer	3.183	0.0	2624
4320 min Summer	2.351	0.0	3328
5760 min Summer	1.897	0.0	4096
7200 min Summer	1.606	0.0	4904
8640 min Summer	1.401	0.0	5792
10080 min Summer	1.249	0.0	6560
15 min Winter	134.458	0.0	19

©1982-2020 Innovyze

Summary of Results for 100 year Return Period (+40%)

Storm Event	Max Level (m)	Max Depth (m)	Max Infiltration (l/s)	Max Volume (m³)	Status
30 min Winter	22.625	0.525	0.6	143.8	O K
60 min Winter	22.721	0.621	0.7	178.8	O K
120 min Winter	22.829	0.729	0.8	221.8	O K
180 min Winter	22.897	0.797	0.8	250.9	O K
240 min Winter	22.947	0.847	0.9	273.5	O K
360 min Winter	23.020	0.920	0.9	307.9	O K
480 min Winter	23.073	0.973	1.0	333.9	O K
600 min Winter	23.114	1.014	1.0	354.9	Flood Risk
720 min Winter	23.147	1.047	1.0	372.4	Flood Risk
960 min Winter	23.172	1.072	1.0	385.8	Flood Risk
1440 min Winter	23.200	1.100	1.1	401.1	Flood Risk
2160 min Winter	23.215	1.115	1.1	409.4	Flood Risk
2880 min Winter	23.215	1.115	1.1	409.2	Flood Risk
4320 min Winter	23.218	1.118	1.1	410.7	Flood Risk
5760 min Winter	23.215	1.115	1.1	409.4	Flood Risk
7200 min Winter	23.206	1.106	1.1	404.2	Flood Risk
8640 min Winter	23.193	1.093	1.1	396.9	Flood Risk
10080 min Winter	23.177	1.077	1.0	388.2	Flood Risk

Storm Event	Rain (mm/hr)	Flooded Volume (m³)	Time-Peak (mins)
30 min Winter	83.947	0.0	34
60 min Winter	52.411	0.0	64
120 min Winter	32.722	0.0	122
180 min Winter	24.841	0.0	182
240 min Winter	20.430	0.0	242
360 min Winter	15.509	0.0	360
480 min Winter	12.755	0.0	478
600 min Winter	10.960	0.0	596
720 min Winter	9.683	0.0	714
960 min Winter	7.687	0.0	944
1440 min Winter	5.551	0.0	1410
2160 min Winter	4.009	0.0	2080
2880 min Winter	3.183	0.0	2736
4320 min Winter	2.351	0.0	3460
5760 min Winter	1.897	0.0	4376
7200 min Winter	1.606	0.0	5328
8640 min Winter	1.401	0.0	6224
10080 min Winter	1.249	0.0	7152

©1982-2020 Innovyze

Rainfall Details

Rainfall Model	FEH
Return Period (years)	100
FEH Rainfall Version	1999
Site Location	GB 460850 105450 SU 60850 05450
C (1km)	-0.026
D1 (1km)	0.440
D2 (1km)	0.317
D3 (1km)	0.373
E (1km)	0.301
F (1km)	2.238
Summer Storms	Yes
Winter Storms	Yes
Cv (Summer)	0.750
Cv (Winter)	0.840
Shortest Storm (mins)	15
Longest Storm (mins)	10080
Climate Change %	+40

Time Area Diagram

Total Area (ha) 0.410

Time (mins) From:	To:	Area (ha)
0	4	0.410

©1982-2020 Innovyze

Model Details

Storage is Online Cover Level (m) 23.400

Infiltration Basin Structure

Invert Level (m) 22.100 Safety Factor 2.0
Infiltration Coefficient Base (m/hr) 0.00828 Porosity 1.00
Infiltration Coefficient Side (m/hr) 0.00828

Depth (m)	Area (m²)	Depth (m)	Area (m²)
0.000	204.9	1.300	633.4

©1982-2020 Innovyze

Summary of Results for 100 year Return Period (+40%)

Half Drain Time : 3278 minutes.

Storm Event	Max Level (m)	Max Depth (m)	Max Infiltration (l/s)	Max Volume (m³)	Status
15 min Summer	23.394	0.594	1.7	321.5	O K
30 min Summer	23.485	0.685	2.0	400.5	O K
60 min Summer	23.585	0.785	2.2	497.9	O K
120 min Summer	23.694	0.894	2.5	616.8	O K
180 min Summer	23.760	0.960	2.7	697.1	O K
240 min Summer	23.808	1.008	2.9	758.9	O K
360 min Summer	23.877	1.077	3.1	852.4	O K
480 min Summer	23.926	1.126	3.2	922.6	O K
600 min Summer	23.963	1.163	3.3	978.5	O K
720 min Summer	23.993	1.193	3.4	1024.5	O K
960 min Summer	24.013	1.213	3.5	1056.8	Flood Risk
1440 min Summer	24.032	1.232	3.5	1088.3	Flood Risk
2160 min Summer	24.036	1.236	3.5	1094.7	Flood Risk
2880 min Summer	24.033	1.233	3.5	1088.9	Flood Risk
4320 min Summer	24.040	1.240	3.6	1100.2	Flood Risk
5760 min Summer	24.038	1.238	3.6	1098.0	Flood Risk
7200 min Summer	24.032	1.232	3.5	1087.3	Flood Risk
8640 min Summer	24.022	1.222	3.5	1071.6	Flood Risk
10080 min Summer	24.011	1.211	3.5	1053.3	Flood Risk
15 min Winter	23.440	0.640	1.9	360.2	O K

Storm Event	Rain (mm/hr)	Flooded Volume (m³)	Time-Peak (mins)
15 min Summer	134.458	0.0	19
30 min Summer	83.947	0.0	34
60 min Summer	52.411	0.0	64
120 min Summer	32.722	0.0	124
180 min Summer	24.841	0.0	184
240 min Summer	20.430	0.0	244
360 min Summer	15.509	0.0	364
480 min Summer	12.755	0.0	482
600 min Summer	10.960	0.0	602
720 min Summer	9.683	0.0	722
960 min Summer	7.687	0.0	962
1440 min Summer	5.551	0.0	1442
2160 min Summer	4.009	0.0	2100
2880 min Summer	3.183	0.0	2420
4320 min Summer	2.351	0.0	3156
5760 min Summer	1.897	0.0	3976
7200 min Summer	1.606	0.0	4824
8640 min Summer	1.401	0.0	5624
10080 min Summer	1.249	0.0	6456
15 min Winter	134.458	0.0	19

©1982-2020 Innovyze

Summary of Results for 100 year Return Period (+40%)

Storm Event	Max Level (m)	Max Depth (m)	Max Infiltration (l/s)	Max Volume (m³)	Status
30 min Winter	23.536	0.736	2.1	448.7	O K
60 min Winter	23.642	0.842	2.4	558.0	O K
120 min Winter	23.756	0.956	2.7	691.5	O K
180 min Winter	23.826	1.026	2.9	782.0	O K
240 min Winter	23.877	1.077	3.1	851.7	O K
360 min Winter	23.949	1.149	3.3	957.5	O K
480 min Winter	24.001	1.201	3.4	1037.1	Flood Risk
600 min Winter	24.040	1.240	3.6	1100.8	Flood Risk
720 min Winter	24.072	1.272	3.7	1153.6	Flood Risk
960 min Winter	24.094	1.294	3.7	1192.2	Flood Risk
1440 min Winter	24.118	1.318	3.8	1233.0	Flood Risk
2160 min Winter	24.127	1.327	3.8	1249.6	Flood Risk
2880 min Winter	24.122	1.322	3.8	1241.1	Flood Risk
4320 min Winter	24.125	1.325	3.8	1245.7	Flood Risk
5760 min Winter	24.119	1.319	3.8	1235.4	Flood Risk
7200 min Winter	24.106	1.306	3.8	1213.4	Flood Risk
8640 min Winter	24.090	1.290	3.7	1185.2	Flood Risk
10080 min Winter	24.072	1.272	3.7	1154.1	Flood Risk

Storm Event	Rain (mm/hr)	Flooded Volume (m³)	Time-Peak (mins)
30 min Winter	83.947	0.0	34
60 min Winter	52.411	0.0	64
120 min Winter	32.722	0.0	122
180 min Winter	24.841	0.0	182
240 min Winter	20.430	0.0	240
360 min Winter	15.509	0.0	358
480 min Winter	12.755	0.0	476
600 min Winter	10.960	0.0	594
720 min Winter	9.683	0.0	712
960 min Winter	7.687	0.0	944
1440 min Winter	5.551	0.0	1400
2160 min Winter	4.009	0.0	2072
2880 min Winter	3.183	0.0	2680
4320 min Winter	2.351	0.0	3332
5760 min Winter	1.897	0.0	4264
7200 min Winter	1.606	0.0	5184
8640 min Winter	1.401	0.0	6056
10080 min Winter	1.249	0.0	6960

©1982-2020 Innovyze

Rainfall Details

Rainfall Model	FEH
Return Period (years)	100
FEH Rainfall Version	1999
Site Location	GB 460850 105450 SU 60850 05450
C (1km)	-0.026
D1 (1km)	0.440
D2 (1km)	0.317
D3 (1km)	0.373
E (1km)	0.301
F (1km)	2.238
Summer Storms	Yes
Winter Storms	Yes
Cv (Summer)	0.750
Cv (Winter)	0.840
Shortest Storm (mins)	15
Longest Storm (mins)	10080
Climate Change %	+40

Time Area Diagram

Total Area (ha) 1.280

Time (mins) From:	To:	Area (ha)
0	4	1.280

©1982-2020 Innovyze

Model Details

Storage is Online Cover Level (m) 24.300

Infiltration Basin Structure

Invert Level (m) 22.800 Safety Factor 2.0
Infiltration Coefficient Base (m/hr) 0.00828 Porosity 1.00
Infiltration Coefficient Side (m/hr) 0.00828

Depth (m)	Area (m²)	Depth (m)	Area (m²)
0.000	308.0	1.500	2058.0

©1982-2020 Innovyze

Summary of Results for 100 year Return Period (+40%)

Half Drain Time : 9027 minutes.

Storm Event	Max Level (m)	Max Depth (m)	Max Infiltration (l/s)	Max Volume (m³)	Status
15 min Summer	17.956	0.506	3.1	1094.1	O K
30 min Summer	18.070	0.620	3.3	1364.3	O K
60 min Summer	18.207	0.757	3.5	1699.6	O K
120 min Summer	18.368	0.918	3.8	2113.7	O K
180 min Summer	18.475	1.025	4.0	2398.1	O K
240 min Summer	18.557	1.107	4.1	2620.7	O K
360 min Summer	18.680	1.230	4.4	2965.3	O K
480 min Summer	18.772	1.322	4.5	3232.3	O K
600 min Summer	18.847	1.397	4.7	3452.2	O K
720 min Summer	18.910	1.460	4.8	3639.8	O K
960 min Summer	18.965	1.515	4.9	3807.7	O K
1440 min Summer	19.038	1.588	5.0	4033.2	O K
2160 min Summer	19.100	1.650	5.1	4229.3	O K
2880 min Summer	19.134	1.684	5.2	4337.3	O K
4320 min Summer	19.194	1.744	5.3	4532.5	O K
5760 min Summer	19.217	1.767	5.3	4605.3	O K
7200 min Summer	19.222	1.772	5.3	4621.1	O K
8640 min Summer	19.223	1.773	5.3	4625.9	O K
10080 min Summer	19.221	1.771	5.3	4619.7	O K
15 min Winter	18.012	0.562	3.2	1225.6	O K

Storm Event	Rain (mm/hr)	Flooded Volume (m³)	Time-Peak (mins)
15 min Summer	134.458	0.0	19
30 min Summer	83.947	0.0	34
60 min Summer	52.411	0.0	64
120 min Summer	32.722	0.0	124
180 min Summer	24.841	0.0	184
240 min Summer	20.430	0.0	244
360 min Summer	15.509	0.0	364
480 min Summer	12.755	0.0	484
600 min Summer	10.960	0.0	604
720 min Summer	9.683	0.0	724
960 min Summer	7.687	0.0	964
1440 min Summer	5.551	0.0	1442
2160 min Summer	4.009	0.0	2164
2880 min Summer	3.183	0.0	2880
4320 min Summer	2.351	0.0	4320
5760 min Summer	1.897	0.0	5760
7200 min Summer	1.606	0.0	6552
8640 min Summer	1.401	0.0	7256
10080 min Summer	1.249	0.0	7968
15 min Winter	134.458	0.0	19

©1982-2020 Innovyze

Summary of Results for 100 year Return Period (+40%)

Storm Event	Max Level (m)	Max Depth (m)	Max Infiltration (l/s)	Max Volume (m³)	Status
30 min Winter	18.138	0.688	3.4	1528.5	O K
60 min Winter	18.287	0.837	3.7	1904.6	O K
120 min Winter	18.465	1.015	4.0	2369.3	O K
180 min Winter	18.582	1.132	4.2	2689.2	O K
240 min Winter	18.671	1.221	4.3	2939.7	O K
360 min Winter	18.805	1.355	4.6	3328.0	O K
480 min Winter	18.906	1.456	4.8	3629.5	O K
600 min Winter	18.988	1.538	4.9	3878.3	O K
720 min Winter	19.056	1.606	5.0	4091.1	O K
960 min Winter	19.117	1.667	5.1	4284.3	O K
1440 min Winter	19.199	1.749	5.3	4547.2	O K
2160 min Winter	19.271	1.821	5.4	4782.9	O K
2880 min Winter	19.312	1.862	5.5	4920.8	O K
4320 min Winter	19.388	1.938	5.6	5175.4	O K
5760 min Winter	19.423	1.973	5.7	5295.6	O K
7200 min Winter	19.436	1.986	5.7	5340.6	O K
8640 min Winter	19.436	1.986	5.7	5339.7	O K
10080 min Winter	19.428	1.978	5.7	5314.4	O K

Storm Event	Rain (mm/hr)	Flooded Volume (m³)	Time-Peak (mins)
30 min Winter	83.947	0.0	34
60 min Winter	52.411	0.0	64
120 min Winter	32.722	0.0	124
180 min Winter	24.841	0.0	182
240 min Winter	20.430	0.0	242
360 min Winter	15.509	0.0	362
480 min Winter	12.755	0.0	480
600 min Winter	10.960	0.0	598
720 min Winter	9.683	0.0	716
960 min Winter	7.687	0.0	954
1440 min Winter	5.551	0.0	1428
2160 min Winter	4.009	0.0	2124
2880 min Winter	3.183	0.0	2824
4320 min Winter	2.351	0.0	4192
5760 min Winter	1.897	0.0	5536
7200 min Winter	1.606	0.0	6840
8640 min Winter	1.401	0.0	8040
10080 min Winter	1.249	0.0	8368

©1982-2020 Innovyze

Rainfall Details

Rainfall Model	FEH
Return Period (years)	100
FEH Rainfall Version	1999
Site Location	GB 460850 105450 SU 60850 05450
C (1km)	-0.026
D1 (1km)	0.440
D2 (1km)	0.317
D3 (1km)	0.373
E (1km)	0.301
F (1km)	2.238
Summer Storms	Yes
Winter Storms	Yes
Cv (Summer)	0.750
Cv (Winter)	0.840
Shortest Storm (mins)	15
Longest Storm (mins)	10080
Climate Change %	+40

Time Area Diagram

Total Area (ha) 4.350

Time (mins) From:	To:	Area (ha)
0	4	4.350

©1982-2020 Innovyze

Model Details

Storage is Online Cover Level (m) 19.750

Infiltration Basin Structure

Invert Level (m) 17.450 Safety Factor 2.0
Infiltration Coefficient Base (m/hr) 0.00828 Porosity 1.00
Infiltration Coefficient Side (m/hr) 0.00828

Depth (m)	Area (m²)	Depth (m)	Area (m²)
0.000	1999.1	2.300	3708.7

©1982-2020 Innovyze

Summary of Results for 100 year Return Period (+40%)

Half Drain Time : 3821 minutes.

Storm Event	Max Level (m)	Max Depth (m)	Max Infiltration (l/s)	Max Volume (m³)	Status
15 min Summer	13.270	0.170	2.9	401.1	O K
30 min Summer	13.311	0.211	3.0	499.4	O K
60 min Summer	13.360	0.260	3.1	620.3	O K
120 min Summer	13.418	0.318	3.2	767.5	O K
180 min Summer	13.458	0.358	3.2	866.9	O K
240 min Summer	13.488	0.388	3.3	943.5	O K
360 min Summer	13.532	0.432	3.4	1059.4	O K
480 min Summer	13.566	0.466	3.4	1146.6	O K
600 min Summer	13.592	0.492	3.5	1216.6	O K
720 min Summer	13.614	0.514	3.5	1274.6	O K
960 min Summer	13.629	0.529	3.5	1314.8	O K
1440 min Summer	13.644	0.544	3.6	1355.1	O K
2160 min Summer	13.648	0.548	3.6	1365.0	O K
2880 min Summer	13.640	0.540	3.6	1345.1	O K
4320 min Summer	13.636	0.536	3.6	1332.6	O K
5760 min Summer	13.627	0.527	3.5	1309.8	O K
7200 min Summer	13.617	0.517	3.5	1282.8	O K
8640 min Summer	13.606	0.506	3.5	1253.7	O K
10080 min Summer	13.595	0.495	3.5	1223.4	O K
15 min Winter	13.290	0.190	3.0	449.5	O K

Storm Event	Rain (mm/hr)	Flooded Volume (m³)	Time-Peak (mins)
15 min Summer	134.458	0.0	19
30 min Summer	83.947	0.0	34
60 min Summer	52.411	0.0	64
120 min Summer	32.722	0.0	124
180 min Summer	24.841	0.0	184
240 min Summer	20.430	0.0	244
360 min Summer	15.509	0.0	364
480 min Summer	12.755	0.0	482
600 min Summer	10.960	0.0	602
720 min Summer	9.683	0.0	722
960 min Summer	7.687	0.0	962
1440 min Summer	5.551	0.0	1442
2160 min Summer	4.009	0.0	2160
2880 min Summer	3.183	0.0	2796
4320 min Summer	2.351	0.0	3460
5760 min Summer	1.897	0.0	4256
7200 min Summer	1.606	0.0	5048
8640 min Summer	1.401	0.0	5880
10080 min Summer	1.249	0.0	6752
15 min Winter	134.458	0.0	19

©1982-2020 Innovyze

Summary of Results for 100 year Return Period (+40%)

Storm Event	Max Level (m)	Max Depth (m)	Max Infiltration (l/s)	Max Volume (m³)	Status
30 min Winter	13.335	0.235	3.0	559.7	O K
60 min Winter	13.390	0.290	3.1	695.5	O K
120 min Winter	13.456	0.356	3.2	861.4	O K
180 min Winter	13.499	0.399	3.3	973.8	O K
240 min Winter	13.533	0.433	3.4	1060.5	O K
360 min Winter	13.583	0.483	3.5	1192.6	O K
480 min Winter	13.621	0.521	3.5	1292.6	O K
600 min Winter	13.651	0.551	3.6	1373.1	O K
720 min Winter	13.676	0.576	3.6	1440.3	O K
960 min Winter	13.694	0.594	3.7	1489.9	O K
1440 min Winter	13.714	0.614	3.7	1544.4	O K
2160 min Winter	13.723	0.623	3.7	1570.0	O K
2880 min Winter	13.721	0.621	3.7	1562.3	O K
4320 min Winter	13.715	0.615	3.7	1547.7	O K
5760 min Winter	13.704	0.604	3.7	1517.2	O K
7200 min Winter	13.691	0.591	3.6	1480.4	O K
8640 min Winter	13.675	0.575	3.6	1437.2	O K
10080 min Winter	13.658	0.558	3.6	1391.0	O K

Storm Event	Rain (mm/hr)	Flooded Volume (m³)	Time-Peak (mins)
30 min Winter	83.947	0.0	34
60 min Winter	52.411	0.0	64
120 min Winter	32.722	0.0	122
180 min Winter	24.841	0.0	182
240 min Winter	20.430	0.0	240
360 min Winter	15.509	0.0	360
480 min Winter	12.755	0.0	478
600 min Winter	10.960	0.0	596
720 min Winter	9.683	0.0	714
960 min Winter	7.687	0.0	950
1440 min Winter	5.551	0.0	1412
2160 min Winter	4.009	0.0	2096
2880 min Winter	3.183	0.0	2764
4320 min Winter	2.351	0.0	3976
5760 min Winter	1.897	0.0	4496
7200 min Winter	1.606	0.0	5408
8640 min Winter	1.401	0.0	6392
10080 min Winter	1.249	0.0	7264

©1982-2020 Innovyze

Rainfall Details

Rainfall Model	FEH
Return Period (years)	100
FEH Rainfall Version	1999
Site Location	GB 460850 105450 SU 60850 05450
C (1km)	-0.026
D1 (1km)	0.440
D2 (1km)	0.317
D3 (1km)	0.373
E (1km)	0.301
F (1km)	2.238
Summer Storms	Yes
Winter Storms	Yes
Cv (Summer)	0.750
Cv (Winter)	0.840
Shortest Storm (mins)	15
Longest Storm (mins)	10080
Climate Change %	+40

Time Area Diagram

Total Area (ha) 1.600

Time (mins) From:	To:	Area (ha)
0	4	1.600

©1982-2020 Innovyze

Model Details

Storage is Online Cover Level (m) 14.400

Infiltration Basin Structure

Invert Level (m) 13.100 Safety Factor 2.0
Infiltration Coefficient Base (m/hr) 0.00828 Porosity 1.00
Infiltration Coefficient Side (m/hr) 0.00828

Depth (m)	Area (m²)	Depth (m)	Area (m²)
0.000	2300.0	1.300	3269.0

©1982-2020 Innovyze