

Tim Wall

From: Charles Forster <Charles.Forster@hantsfire.gov.uk>
Sent: 27 June 2022 07:44
To: Tim Wall
Subject: Newgate Lane East, Gosport, PO14 1AZ

CAUTION: This message originated outside of i-Transport. Use caution when opening attachments, clicking links or responding to requests for information.

Good Morning Tim

With regard to confirmation of access for this project, I will refer you to the letter precisely sent and comments contained within it, if the site complies with the requirements of ADB Vol1 and the FSA then it is likely that it will be suitable, any areas not within the minimum parameters will need compensatory factors installed. Such as domestic sprinklers or improved access.

There are no further comments currently.

Regards

Charles Bartholomew Forster
Fire Engineering & Consultation Team Advisor
Fire Engineering & Consultation Team
Tel: 023 8064 4000 Extension: 759-8250 & 753-4744
Email: charles.forster@hantsfire.gov.uk

This transmission is intended for the named addressee(s) only and may contain material classified as OFFICIAL SENSITIVE and should be handled accordingly. Unless you are the named addressee (or authorised to receive it for the addressee) you may not copy or use it, or disclose it to anyone else. If you have received this transmission in error and / or are uncertain of the implications please notify the sender immediately. This email has been scanned for content and viruses.